

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:00 pm

PWS ID: UTAH26059 **Name:** WASATCH MOBILE HOME PARK
Legal Contact: WASATCH MOBILE HOME PARK **Rating:**
SHAURELLE ORGILL **Rating Date:**
Address: 3000 S Daniels Rd **Activity Status:** Active
HEBER CITY, UT 84032
Phone Number:
City Served (Area):
County: WASATCH COUNTY
System Type: Non-public **Last Inv Update:** 02/08/2008 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/08/2008 **Total Dsgn Cap:**
Population: 18 **Surveyor:** DWIGHT HILL **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	ORGILL, SHAURELLE				

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	10
			10 Total Svc Connections

Storage

Total Storage: 300 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	300 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	MHP WELL 1	Active	WL	8	30 GPM	30 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.